# DOC. NAME: DOC. No. DAD-PVR-001(\*688) PCBA FUNCTION TEST STATION **REV** A INSTALLATION AND OPERATION **EFFECTIVE** QUALIFICATION **PAGE** 1 of 9 Healthcare Technology International Ltd. DOC NAME: PCBA FUNCTIONAL TEST STATION INSTALLATION AND OPERATION **QUALIFICATION** DOC. No.: DAD-PVR-001(#688) Rev: A **Revision History of Protocol** Description of change Effective date Rev. First issue Α Report No.: Equipment / Fixture No.: Rev: Date: **Revision History of Report** Effective date Rev. Description of change Distributed to: DA,QA,PIE,R&D

FORM-0001A

DOC. NAME:	DOC. No.	DAD-PVR-001(#688)
PCBA FUNCTION TEST STATION	REV	A
INSTALLATION AND OPERATION	EFFECTIVE	
QUALIFICATION	PAGE	2 of 9

### **Protocol Approval**

Completion of the follo		ck signifies the approv	<u>L</u>	
Prepared by:	0 0		1	
Reviewed by:	<del>_</del> _	<del>_</del>	<del>_</del>	
DEPT.	TITLE	NAME	SIGNATURE	DATE
DA /QA	Manager	Percy Wong		
R&D/ELE	Manager	Stephen Ng		
R&D/Proj. MEC	Manager	Wingo Tang		
PIE	Manager	王文伟		
PROD	Manager	Ben Wong		
Approved by:				
RESPONSIBILITY	TITLE	NAME	SIGNATURE	DATE
MGT	DGM	Erik Lee		

# Qualification

Completion of the following signature block signifies the protocol has been fully implemented, all the typing data have been double-check with raw data in attached sheets, and the results have been reviewed by and found acceptable

Prepared by:	Date:	
Reviewed by:		

DEPT.& TITLE	NAME	SIGNATURE & DATE	The report has been reviewed and meets all acceptance criteria	The report has been reviewed and doesn't meets all acceptance criteria(delete as appropriate)
DA /QA	Percy Wong			Accepted*/Not accepted
R&D/ELE	Stephen Ng			Accepted*/Not accepted
R&D/Proj. MEC	Wingo Tang			Accepted*/Not accepted
PIE	王文伟			Accepted*/Not accepted
PROD	Ben Wong			Accepted*/Not accepted

Approved by:

				The report has been reviewed
RESP.&	NAME	SIGNATURE &	reviewed and meets	and doesn't meets all
			all acceptance	acceptance criteria(delete as
TITLE		DATE		appropriate)
MGT	Erik Lee			Accepted*/Not accepted

<sup>\*----</sup>Accepted as the exceptions have no detrimental effect upon the product.

# 1.0 Purpose

DOC. NAME:	DOC. No.	DAD-PVR-001(#688)
PCBA FUNCTION TEST STATION	REV	A
INSTALLATION AND OPERATION	EFFECTIVE	
QUALIFICATION	PAGE	3 of 9

The purpose of this installation and operational qualification is to verify that the PCBA functional tester (Process code: Q020, PCBA Functional station) of HTI-#688 has been installed in accordance with design criteria, engineering specifications, user requirements, and that the system documentation is correct and complete. The purpose is also to verify that equipment operating procedure are suitable to assure consistent operation, and instrument calibrations have been performed.

#### 2.0 Scope

This procedure applies to the installation and operation of PCBA functional test station (Process code: Q020) of HTI-#688. The scope of this protocol will validate the installation, process procedures, and the ability of the test system to detect the PCBA defects. A quantity of "pass" operator inspected PCBA will be tested by the test system to validate the systems ability to determine response pass/fail.

#### 3.0 Ref. Document

PFC-688-01: Process Flow Chat

QCI-688-02: QC Functional Test Instruction

DAD-EVR-000(#688) Equipment Validation Master Plan For #688 (MicroStim)

#### 4.0 Equipment Required

4.1 PCBA Functional tester.

#### 5.0 Equipment description

5.1 The functional tester is used to read the program of the PCBA's chip.

#### 6.0 Procedure

- 6.1 The qualified technician should study carefully relevant technical documents provided by R&D/DA.
- 6.2Connect the power supply cord of the multi-meter into 220V power supply socket.
- 6.3PCBA test procedure:
  - 6.3.1 Place and fix the PCBA to the tester.
  - 6.3.2 Press the "test" switch to begin the test.
  - 6.6.3 After finished the test, the LCD will display "waiting for testing....". Then push the switch "UP" or "down" to check the test results of last under test device.

#### 7.0 Product Characteristics

- 7.1 The LED flash with the pulse output.
- 7.2 Sound generates when the load is about  $1K\Omega$ .
- 7.3 Four class pulses output at the difference modes (T.O.F., D.B.S., P.T.C. and

	DOG 1	YANG:						и.
		NAME:	TECT OT A	TION	DOC. N	o.	R-001(#688)	
		BA FUNCTION TALLATION AN			REV EFFECTI	REV A		A
	11/0	QUALIFIC		HON	PAGE	·	4.	of 9
		QU'ILII IC	TITOTY		TAGE	, <u> </u>		01 9
	1Hz)							
8.0 Proces	ss Para	ameters and C	ontrol Co	ndition	S			
8.1 P	ower so	ource:		220 <u>+</u> 109	% V/AC			
9.0 Instal	lation	Qualification						
engi	ineer an	e necessity of the d has been sticke following sheet:			•		•	
Fixture ment		Fixture/Equipme No.	ent Drawi	ing No.		ration rt No:	Dura	tion
Fix	ture							
9.2C	rmed by	y:the necessity of the have been fulfill	ne supply ar	nd the am	bient cond	litions fo	or the	
Item	Specif	fied temperature	Mains	Sp	ecified	Act	ual cond	dition
100111		(1)	power(2)	hum	idity (2)	(1)	(2)	(3)
Parameter		20-25°C		60	)-80%			
Test equipment	Tem	np & Humidity Meter	Multi-mete	er				
Calibration No.								
Comr	nent:							
Perfo	rmed by	y:	Date:					
9.3In	stall the	e fixture correctly	, check and	record tl	ne materia	ls used.	DA is re	esponsible

# DOC. NAME:DOC. No.DAD-PVR-001(#688)PCBA FUNCTION TEST STATIONREVAINSTALLATION AND OPERATIONEFFECTIVEQUALIFICATIONPAGE5 of 9

to confirm the setup correctly as per the requirements established.

Comment:		
Installed by:	Checked by:	

- 9.4Adjust the tester to reach the following requirements:
  - 9.4.1 Push the switch up and down to check 4 modes output results.
  - 9.4.2 LCD displays the amount and the interval of the pulse.
  - 9.4.3 Can the switches be adjusted in right positions? Are there clearly label indicated for the positions?
  - 9.4.4 Can fixture fix the sample firmly in right position for test?
  - 9.4.5 Can the parameters ensure a quality result? If not, DA engineer should instruct the technician to adjust the relative parameters recorded.

Item	Parameter/func	Specification	Inspection	Result
	tion		method	
1	switch	Can be pushed up and		
	locations	down		
2	LCD display	displays the amount and		
		the interval of the pulse		
3	fixture	fix the sample firmly		

Comment:		
Performed by:	_Date:	-
Signature: PIE:	QA:	_ DA

- 9.5Prepare the daily and the periodic maintenance record according to the <<Equipment Prevention and Maintenance Procedure>>(HCQSP.9.3).
- 9.6Prepare the records of calibration according to the <<Calibration Control Procedure>> (HCQSP11.1).

DOC. NAME:	DOC. No.	DAD-PVR-001(*688)
PCBA FUNCTION TEST STATION	REV	A
INSTALLATION AND OPERATION	EFFECTIVE	
QUALIFICATION	PAGE	6 of 9

#### 10.0 Operation Qualification

- 10.1 Having installed the test station and auxiliary parts, confirm that the IQ Requirements have been fulfilled.
- 10.2 Training the operator on the station. And store the training records in QA dept.
- 10.3 If the inspector found any deviation in this station, let his Supervisor know and decide how to do. It includes two methods: One is to repair the test station/or debug program control or fixtures; the second is to stop production to solve the problem.
- 10.4 Conduct the daily and the periodic maintenance by DA/QA according to the <<Tester Prevention and Maintenance Procedure>> (HCQSP9.3).

  And store the records in DA dept.
- 10.5 Conduct calibration according to the <<Calibration Control Procedure>> (HCQSP11.1) and store the records in DA dept.
- 10.6 Conduct 30 pcs #688 sample and 8 know bad boards to confirm the Functional Test station. Record down all the test parameters of the samples in difference switches positions; fill in the appendix A & B.

#### 11.0 Acceptance criteria for IQ/OQ

- 11.1 The necessary documents must be completed.
- 11.2 Fulfill the requirements mentioned in clause 9.1, 9.2 and 9.3. The tester can be operated freely without any damage and can play all its preset functions consistently.
- 11.3 The samples performances meet the #688 Test Procedure requirements.
- 11.4 All the test results of appendix A failed and all the test results of appendix B passed bade on the testing specification specified at appendix C.

#### 12.0 Conclusion

Signature: PIE:	_QA:	_DA:
Dare:	Date:	Date:

DOC. NAME:	DOC. No.	DAD-PVR-001(#688)
PCBA FUNCTION TEST STATION	REV	A
INSTALLATION AND OPERATION	EFFECTIVE	
QUALIFICATION	PAGE	7 of 9

# Appendix A (Know bad board test record):

# Operation verification items

u		ecor	u):							
	Result									
1Hz mode										
1Hz										
	P/F									
P.T.C. mode	interval amount of plus of plus									
P.T.C.	interval of plus		e 5							
	width of interval amount plus of plus of plus									
	P/F									
D.B.S. mode	amount of plus									
D.B.S.	interval amount of plus of plus									
	width of interval amount plus of plus									
	P/F									
mode	amount of plus									
T.O.F. mode	width of interval amount plus of plus									
	width of plus									
		IC pin 17 open	IC pin 8 open	IC pin 9 open	IC pin 10 open	IC pin 11 open	IC pin 12 open	IC pin 13 open	IC pin 8&9 open	
Sample Failure No item		1	2 0	3	4 6	5 1	9	7	× ×	

		D	OC	C. 1	NA	λN	1E	•															]	DC	ЭC	. N	o.				D/	AD-	-PVR-0	001(	<sup>#</sup> 688)
	PCBA FUNCTION TEST STATION INSTALLATION AND OPERATION OUALIFICATION																RE			_		A													
QUALIFICATION QUALIFICATION													EFFECTIVE PAGE							8 of 9															
		<u> </u>																				<u> </u>				<u> </u>							0 01		
Append	ix —	<b>B</b> ()	Kno	OW	g	00	d	bo	a	rd	te	est	r	ec	or	<b>d</b> )	:			_		_	_	_		_	_	_	_			$\Box$	P		
		Result																													1000				
	1Hz mode		1	Ц																								4				Ц			
	1Hz							$\perp$	_																$\perp$	_	4					Ц			
	L		$\perp$																					-								Ц			
		P/F																																	
927	mode	amount	or prins					71																											
verification items	P.T.C.	-	or pius																		15														DA:
ation		4	bins																																
erific		P/F v																																	
	opou	amount	or pius																																
Operation	D.B.S. mode	$\overline{}$	or prus																									1					Date:		Q A:
		দ	Snid																									1				Н			0
ω.		P/F w																					100000									H	e <sup>‡</sup>		
	ode	amount	or pius																													H			
	T.O.F. mode	_	or pius o																		(1										-		bv:		PIE:
€3		4	smd																														Performed bv:		Signature:PIE:
		No No	-	2	8	4	5	9	7	∞	6	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	22	56	27	28	53	30	Per	1	Sig

DOC. NAME:	DOC. No.	DAD-PVR-001(*688)
PCBA FUNCTION TEST STATION	REV	A
INSTALLATION AND OPERATION	EFFECTIVE	
QUALIFICATION	PAGE	9 of 9

# **Appendix C: Testing specification**

T.O.F. mode			D	B.S. mod	le	P.	T.C. mod	de	1 Hz mode				
Width	Interval	Sum of											
of plus	of plus	plus											
200NS	2N2	4											