



## **Belling Lee Limited**

540 Great Cambridge Road, Enfield, Middlesex EN1 3RY  
Telephone: 01-363 5393 Telex 263265

COPIES OF APPROVAL CERTIFICATES  
FOR L.2002. FUSEHOLDER.

NOTE:- SEMKO CERT. No,  
IS 42/78729.

**with compliments**

(BUT CERTIFICATE HAS BEEN  
MISLAID.)

*J. T. Nlong*  
11/4/88.

A member of the Cambridge Electronic Industries Group  
Registered Office: Botanic House, 100 Hills Road, Cambridge CB2 1LQ. Registered in London No. 186538

20 x 5mm

**BELLING-LEE**



L (overall) = 34.7  
Dia. (bezel) = 14.6  
Depth behind panel = 32.7  
Panel cutout = 12.9  
Panel keyway = 1.7 x 1.1  
Panel thickness = 0.9 to 3.6

Low profile fuseholder moulded in flame retardant polyester which meets the safety requirements of BS415, IEC257 and is proof against test pin to BS4042. The screw retained cap with slot is easily removed using a small coin. The fuseholder is UL recognised, SEMKO and VDE approved. Solder tab terminations. Mfrs. List No. L2002.

Rating 6.3A  
Breakdown voltage  $\geq 4kV$  dc

Operating temperature  $-55^{\circ}C$  to  $+70^{\circ}C$