


Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / Installer				Job Address				Customer / Landlord			
Engineer	jules hawley			Name				Name			
Company	jules hawley			Address	13			Company	Wilman & Lodge		
Address	248				Station Road			Address	77		
	Fell Lane				Cross Hills				Main street		
	Keighley				West Yorkshire				Cross hills		
	West Yorkshire				BD20 7EH				North Yorkshire		
Post Code	BD22 6BZ			Tel. No				Post Code			
Tel No.	07930164130							Tel. No			
Gas Safe Reg	536552										
ID Card No.	4684869										

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading		Low Combustion Reading		Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use		
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Compartment	Combination Boiler	Ideal	Instinct 2 24	RS	Yes	Yes	NA	22.66	0.0011	82	7.6	0.0004	32	7.3	Yes	Yes	Yes	Pass	No	Yes
2	Lounge	Fire	Valor	622	OF	Yes	Yes	NA	5.96	NA	NA	NA	NA	NA	NA	Yes	Yes	Yes	Pass	No	Yes
3	Kitchen	Hob	Diplomat	Built-in	FL	Yes	Yes	NA	6.56	NA	NA	NA	NA	NA	NA	Yes	Yes	NA	NA	No	Yes
4																					
5																					
6																					

Defects / Identified				Labels and Warning Notice Issued				CO Alarm(s)				Smoke Alarm(s)				
1							NA	CO Alarm(s) fitted	Yes			Smoke Alarm(s) fitted			Yes	
2							NA	CO Alarm(s) tested and Satisfactory	Pass			Smoke Alarm(s) tested and Satisfactory			Pass	
3							NA									
4																
5																
6																

Emergency Control Accessible <input checked="" type="checkbox"/>	Gas Tightness Satisfactory <input checked="" type="checkbox"/>	Comments
Gas Installation Pipework Visual Inspection Satisfactory <input checked="" type="checkbox"/>	Yes	
Equipotential Bonding <input type="checkbox"/>	No	
NEXT INSPECTION DUE ON OR BEFORE	16-Feb-2024	

Signatures	Issued by:	Signed		Received	Signed by:		Date	10-Feb-2023
Print Name	jules hawley		Print Name					